

# PVC Schedule 40 Pressure Pipe - West

## Conforms to ASTM D 1785

- 1½", 2", 3", 4", 6", 8" conform to the Drain, Waste and Vent (DWV) specification ASTM D 2665
- Certified to requirements of ANSI/NSF 61 and ANSI/NSF 14 for DWV
- Product manufactured with one integral solvent-weld bell per length
- Standard overall pipe length is 20-feet
- Standard color is white



Trade Size	Part Number	Dimensions (in)		Minimum Wall Thickness (in)	Approximate Weight per 100' (lbs)	Water Pressure Rating (psi)	Crate Quantity (ft)
		Avg OD	Approx ID				
½	5405020	0.840	0.61	0.109	16	600	7,200
¾	5407520	1.050	0.81	0.113	22	480	8,000
1	5410020	1.315	1.03	0.133	32	450	5,600
1¼	5412520	1.660	1.35	0.140	43	370	4,400
1½	5415020	1.900	1.59	0.145	52	330	3,600
2	5420020	2.375	2.05	0.154	69	280	2,100
2½	5425020	2.875	2.44	0.203	110	300	1,460
3	5430020	3.500	3.04	0.216	144	260	1,500
4	5440020	4.500	4.00	0.237	205	220	1,140
5	5450020	5.563	5.02	0.258	278	190	760
6	5460020	6.625	6.03	0.280	361	180	520
8*	5480020	8.625	7.92	0.332	559	160	300

\* Schedule 40 is triple marked with ASTM D 1785, ASTM D 2665 and ASTM D 2241. The minimum wall thickness of ASTM D 2241 meets the requirements of all three standards.